


FIRE SAFETY CERTIFICATE

Certified that **Faith Academy** located at **John L. Dorsey Road, Prasad Nagar, New Delhi- 110005** was granted Fire Safety Certificate vide letter No. F.6/DFS/MS/School/SZ/2020/153 dated 13.04.2020 for three blocks- Phase 1, Phase 2 & Phase 3. Phase- 1 is comprised of small basement, ground plus four upper floors & phase- 2 is comprised of ground plus four upper floors & Phase- 3 comprised of basement (sealed by brick wall), ground plus three upper floors and all blocks at upper floors are interconnected at each floor level. The school building was re-inspected by the officers concerned of Delhi Fire Service on 28.04.2023 in the presence of Sh. Anil Lal (Admin) and found that the school management have complied with the fire prevention and fire safety requirements in accordance with Delhi Fire Service Act 2007 and Rules 2010 and that the building/premises is fit for occupancy class "Educational" with effect from 22/05/2023 for a period of 03 years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules. 2010. printed below.

Issued on 22/05/2023 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Principal, Faith Academy, John L. Dorsey Road, Prasad Nagar, New Delhi- 110005.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. Basement shall be used as per BBL.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
9. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.